

7.0 PARTS LIST

ITEM	QTY	DESCRIPTION
1	1	Gas Detection System Control Unit
2	4	F1 0-100% LEL Flammable Gas Sensor

8.0 SERVICE - ROUTINE ATTENTION

The system is designed to operate without the need for major maintenance. However for of mind

control panel for safe operation and investigate/reset any system alarms.

8.2 MONTHLY

Apply certified calibration gas mixtures to the sensors. Observe sensor response and correct operation of all system alarms.

8.3 6-MONTHLY

Perform a full system recalibration. Personnel trained by should only undertake system recalibration.

8.4 ANNUALLY

Inspect full system installation and wiring for integrity.

Perform a full system recalibration. Personnel trained by should only undertake system recalibration.